


**SOUND ABSORPTION AREA FOR OBJECT**

Measured and evaluated according to SS-EN ISO 354 and ISO 20189

Client:	Abstracta		
Object:	dB Pillar 1930		
Size [mm]:	w = 1930	h = 470	d = 369

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.61
125	1.26
250	1.82
500	2.5
1000	2.75
2000	2.75
4000	3.37
N <sub>10</sub> = 4	

**CONDITIONS**

Date of test:	2020-01-10	Object volume:	0.33	m <sup>3</sup>
Date:	2020-03-24	Rev. room volume:	200	m <sup>3</sup>

Test report: KTH-MWL ABSTRACTA 20200107 Object A12  
 Signature: Lars Wester