


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to SS-EN ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Aircone 10 pcs		
Size [mm]:	w = 928	h = 1206	d = 43

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.02
125	0.1
250	0.5
500	0.9
1000	0.9
2000	0.9
4000	0.8
N ₁₀ = 13	



CONDITIONS

Date of test:	2013-11-12	Object volume:	0.05	m ³
Date:	2019-01-20	Rev. room volume:	200	m ³

Test report: Akustikverkstan report 13-137-M7
 Signature: Magnus Karlsson