


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to SS-EN ISO 354 and SS 25269

CLIENT: Abstracta AB

OBJECT: Abstracta Domo Wall panel A4, 4 pcs 0,6*1,2 m assembled together → total area of 2,88 m². Directly mounted on wall.

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)	
	1/3 octave band	Octave band
50	0,03	
63	0,06	0,08
80	0,14	
100	0,17	
125	0,32	0,28
160	0,35	
200	0,46	
250	0,63	0,65
315	0,86	
400	1,15	
500	1,47	1,48
630	1,81	
800	2,25	
1000	2,39	2,33
1250	2,36	
1600	2,33	
2000	2,36	2,29
2500	2,19	
3150	2,19	
4000	2,22	2,24
5000	2,30	



CONDITIONS

Date of test: 2014-09-26

Date: 2015-02-02

Object area: 2,88 m²

Reverberation room volume: 200 m³

Test report: 14-125-M7 dated 2014-09-26 (Akustikverkstan AB, Sweden)

Signature: Delphine Bard